

No.	판넬명	FROM	신설 CABLE SCHEDULE	REMARK
①	L3-A	S/S : LV-17A2	600V F-CV 1C/60sq x 4	
②	L4-A	L3-A	600V F-CV 1C/60sq x 4, GV 14sq (54C)	
③	L5-A	L3-A	600V F-CV 1C/150sq x 4, GV 22sq (82C)	
④	소각열량차일	L5-A	600V F-CV 4C/38sq, GV 8sq (42C)	기존분전반재사용
⑤	L3-B	S/S : LV-17A2	600V F-CV 1C/38sq x 4	
⑥	L3-B-1	L3-B	600V F-CV 4C/38sq, GV 8sq (42C)	기존분전반재사용
⑦	L3-B-1	L3-B	600V F-CV 1C/60sq x 4, GV 14sq (54C)	기존분전반재사용
⑧	L2-A	S/S : LV-17A2	600V F-CV 1C/60sq x 4	
⑨	L2-B	L2-A	600V F-CV 1C/60sq x 4	
⑩	L1-A	S/S : LV-17A2	600V F-CV 1C/60sq x 4, GV 14sq (54C)	기존전선관재사용
⑪	L1-B	L1-A	600V F-CV 1C/60sq x 4, GV 14sq (54C)	
⑫	L1	S/S : LV-17A2	600V F-CV 1C/150sq x 4, GV 38sq (104C)	기존전선관재사용
⑬	L1-1	L1-A	600V F-CV 1C/60sq x 4, GV 14sq (54C)	기존분전반재사용
⑭	LB1-A	S/S : LV-17A2	600V F-CV 1C/60sq x 4	
⑮	LB1-B	S/S : LV-17A2	600V F-CV 1C/100sq x 4	
⑯	L3-C	S/S : LV-17A2	600V F-CV 1C/60sq x 4	기존전선관재사용
⑰	L4-B	S/S : LV-17A2	600V F-CV 1C/200sq x 4, GV 38sq (104C)	
⑱	L5-B	L4-B	600V F-CV 4C/38sq, GV 8sq (42C)	기존분전반재사용
⑲	L4-B-1	L4-B	600V F-CV 1C/150sq x 4, GV 22sq (82C)	
⑳	LO-E	S/S : LV-17A2	600V F-CV 1C/38sq x 4	기존분전반재사용 기존전선관재사용
㉑	LO-B#1	S/S : LV-17A2	600V F-CV 1C/100sq x 4	기존분전반재사용
㉒	LO-A	LO-B#1	600V F-CV 4C/38sq, GV 8sq (42C)	기존분전반재사용
㉓	LO-C	LO-B#1	600V F-CV 1C/150sq x 4, GV 22sq (82C)	
㉔	LO-D	LO-B#1	600V F-CV 1C/60sq, GV 14sq (54C)	
㉕	L1-D	S/S : LV-17A2	600V F-CV 1C/38sq x 4	
㉖	L2-C	S/S : LV-17A2	600V F-CV 1C/60sq x 4	기존전선관재사용
㉗	세종홀 유허실-1	S/S : LV-17A3	600V F-CV 1C/60sq x 4	
㉘	LB1-C	S/S : LV-17A3	600V F-CV 1C/38sq x 4	
㉙	LB1-D	LB1-C	600V F-CV 1C/100sq x 4, GV 22sq (70C)	
㉚	L4-C	S/S : LV-17A2	600V F-CV 1C/100sq x 4	기존전선관재사용

No.	판넬명	FROM	신설 CABLE SCHEDULE	REMARK
①	유허MAIN(컨벤션)	S/S : LV-15A1	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존분전반재사용
②	조명MAIN(컨벤션)	S/S : LV-15A1	600V F-CV 1C/325sq x 4, GV 38sq (104C)	기존분전반재사용
③	아트리카아 MAIN	S/S : LV-17A3	600V F-CV 1C/150sq x 4, GV 38sq (104C)	기존분전반재사용
④	LB2-A	S/S : LV-17A3	600V F-CV 1C/60sq x 4, GV 14sq (70C)	
⑤	LB2-B	LB2-A	600V F-CV 1C/22sq x 4	
⑥	LB1-K	S/S : LV-17A3	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존분전반재사용
⑦	LB2-K	LB1-K	600V F-CV 1C/22sq x 4	기존전선관재사용
⑧	LB3-A	S/S : LV-17A3	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존분전반재사용
⑨	LB2-E	LB3-A	600V F-CV 1C/60sq x 4, GV 14sq (54C)	
⑩	LB2-C	S/S : LV-17A3	600V F-CV 1C/100sq x 4, GV 22sq (82C)	
⑪	LB1-E	LB2-C	600V F-CV 1C/22sq x 4	
⑫	LB2-D	LB2-C	600V F-CV 1C/22sq x 4	
⑬	LB1-F	LB2-D	600V F-CV 1C/22sq x 4	
⑭	L1-L	S/S : LV-17A3	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존분전반재사용
⑮	L1-E	S/S : LV-17A3	600V F-CV 1C/100sq x 4, GV 22sq (82C)	
⑯	대극장아리마	L1-G	600V F-CV 4C/22sq, GV 8sq (54C)	기존분전반재사용
⑰	L2-D	L1-E	600V F-CV 1C/22sq x 4	
⑱	L3-D	L1-E	600V F-CV 1C/22sq x 4	
⑲	L4-D	S/S : LV-17A3	600V F-CV 1C/60sq x 4, GV 14sq (70C)	
⑳	L5-C	L4-D	600V F-CV 1C/22sq x 4	
㉑	L6-A	L4-D	600V F-CV 1C/22sq x 4	
㉒	LB1-H	S/S : LV-17A3	600V F-CV 1C/100sq x 4	
㉓	L1-H	S/S : LV-17A4	600V F-CV 1C/38sq x 4	기존전선관재사용
㉔	L3-G	S/S : LV-17A4	600V F-CV 1C/100sq x 4	
㉕	L4-G	L3-G	600V F-CV 1C/150sq x 4, GV 14sq (54C)	
㉖	L5-G	L3-G	600V F-CV 1C/150sq x 4, GV 22sq (82C)	
㉗	L1-F	S/S : LV-17A4	600V F-CV 1C/100sq x 4, GV 22sq (82C)	
㉘	L2-E	S/S : LV-17A4	600V F-CV 1C/100sq x 4, GV 22sq (82C)	
㉙	TV영상-1	L2-E	600V F-CV 4C/14sq, GV 5.5sq (36C)	
㉚	L3-E	S/S : LV-17A4	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존전선관재사용

No.	판넬명	FROM	신설 CABLE SCHEDULE	REMARK
⑥	L4-E	S/S : LV-17A4	600V F-CV 1C/60sq x 4, GV 14sq (70C)	
⑦	L5-D	S/S : LV-17A4	600V F-CV 1C/60sq x 4, GV 14sq (70C)	기존전선관재사용
⑧	L6-B	S/S : LV-17A4	600V F-CV 1C/60sq x 4, GV 14sq (70C)	
⑨	L1-K	S/S : LV-17A4	600V F-CV 1C/150sq x 4, GV 38sq (104C)	기존분전반재사용
⑩	L1-G	S/S : LV-17A4	600V F-CV 1C/150sq x 4, GV 38sq (104C)	
⑪	L2-F	L1-G	600V F-CV 1C/22sq x 4	
⑫	TV영상-2	L2-F	600V F-CV 4C/14sq, GV 5.5sq (36C)	기존분전반재사용
⑬	L3-F	L1-G	600V F-CV 1C/22sq x 4	
⑭	L4-F	S/S : LV-17A4	600V F-CV 1C/100sq x 4, GV 22sq (82C)	
⑮	L5-E	L4-F	600V F-CV 1C/22sq x 4	
⑯	L6-C	L4-F	600V F-CV 1C/22sq x 4	
⑰	LB2	신관 LV-14A2	600V F-CV 4C/14sq, GV 5.5sq (36C)	
⑱	LB1	신관 LV-14A2	600V F-CV 4C/38sq, GV 14sq (42C)	
⑲	L1	LB1	600V F-CV 4C/14sq, GV 5.5sq (36C)	
㉑	L2	LB1	600V F-CV 4C/14sq, GV 5.5sq (36C)	
㉒	L3	신관 LV-14A2	600V F-CV 1C/100sq x 4, GV 22sq (82C)	기존전선관재사용
㉓	L4	L3	600V F-CV 4C/22sq, GV-8sq (42C)	
㉔	L5	L3	600V F-CV 4C/22sq, GV-8sq (42C)	
㉕	P1	신관 LV-14A2	600V F-CV 4C/38sq, GV 14sq (42C)	기존전선관재사용
㉖	역조명	S/S : LV-22B3	600V F-CV 1C/60sq x 4, GV 14sq (54C)	기존분전반재사용
㉗	세종홀 유허실-2	S/S : LV-17A2	600V F-CV 1C/22sq x 4, GV 5.5sq (42C)	
㉘	L4-B	S/S : LV-17A2	600V F-CV 1C/60sq x 4	
㉙	문수대조명	S/S : LV-17A2	600V F-CV 1C/100sq x 4, GV 22sq (70C)	
㉚	컨벤션 홀	컨벤션 유허	600V F-CV 2C/5.5sq x 4, GV 5.5sq (28C)	
㉛	VIP MAIN 전원	L2-E	600V F-CV 4C/14sq, GV 5.5sq (42C)	
㉜	세종홀주방전등	S/S : LV-22A3	600V F-CV 100sq, GV 22sq (82C)	
㉝	올림픽	세종홀주방전등	600V F-CV 100sq, GV 22sq	
㉞	무대분장실	S/S	600V F-CV 22sq, GV 8sq	
①	선공사 분전반	P-R-MAIN	600V F-CV 70sq/1C x4, PE-35sq (SF2 70C)	코플렉스
②	P-R-A	P-R-MAIN	600V F-CV 6sq/4Cx1, PE-6sq (PE 36C)	
③	P-R-B	P-R-MAIN	600V F-CV 6sq/4Cx1, PE-6sq (PE 36C)	
④	LCP-RA	P-R-MAIN	600V F-CV 6sq/4Cx1, PE-6sq (PE 36C)	
⑤	LCP-RB	P-R-MAIN	600V F-CV 6sq/4Cx1, PE-6sq (PE 36C)	
⑥	L-R-카페	W.H.M	600V F-CV 120sq/1C x4, PE-70sq (SF2 82C)	코플렉스
⑦	P-6급조	기존간선 재사용	600V CV 22sq/4C x1, PE-14sq (SF2 54C)	코플렉스
⑧	W.H.M	LV-17A3	600V F-CV 120sq/1C x4, PE-70sq	트랜지
⑨	P-1-MAIN	기존간선관 활용 전선	600V F-CV 50sq/1Cx4, PE-25sq (SF2 54C)	코플렉스
⑩	LCP-1	P-1-MAIN	600V F-CV 6sq/4Cx1, PE-6sq (PE 36C)	

